FIELD CHECK LIST
FY 1965 UPDATING TASKS

Date Prepared __17 NOV. 1965__

By __C. D. HOWARD.__

A. FACILITY IDENTIFICATION: (Should agree with entries on Form 3706R)

1. Name __WASHINGTON HOTEL__

2. Address __1424 - 1434 F ST NW__

3. S/L __22110063__ F.O. __BC__ Contract __07__ Fac. No. __00387__

B. GENERAL DATA: (Use current L&P File Listing where applicable)

1. Total existing PF Cat 2-8 Spaces: __3363__	2. Total potable water required (B1 x 3.5) gal: __11,770__	3. Issue Stocks On Hand Spaces __0__

4. Water Storage Drums:
   a. Required: (B1 / 5) __673__ Drums   b. Stocked: (B3 / 5) __0__ Drums   c. Balance: (4a - 4b) __673__ Drums

5. Shelter License: Yes____ No____ No Contact_____ Previously Licensed __X__

6. Trapped Water Mod. Permit: Yes____ No____ No Contact __X__ Not Req'd_____

7. Remarks: _____

_____

C. NEW WELL:

1. Estimated Cost $ __2925__   2. Remarks: __150' DEEP WELL W/__ __6" CASING, PUMP, & EMER. GENERATOR.__

D. POTABLE WATER REQTS: (Considering trapped or well water sources shown on Form 3706R)

	Existing Sources	Total (After Modification)
1. Total trapped or well water available:	a. __2900__ gal	b. __2900__ gal
2. Excess (D1-B2) (if negative, enter "0")	a. __0__ gal	b. __0__ gal
3. Equiv stockable spaces (D1 divided by 3.5 - should not exceed B1)	a. __825__ spaces	b. __825__ spaces
4. Equiv drums (D3 divided by 5 - should not exceed B4a)	a. __165__ drums	b. __165__ drums
5. Max drums req'd, incl existing stocks (B4a-D4)	a. __508__ drums	b. __508__ drums
6. Net req't (D5-B4b) (if negative enter "0")	a. __508__ drums	b. __508__ drums

7. Drums owner agrees to accept *_____   8. Remarks: _____

(*)If owner agreement to trapped water modification is obtained disregard D6a and consider D6b as maximum requirement.

Attachment #3   3-1

E. **SANITATION REQUIREMENTS:**
Entries required <u>only</u> if potable trapped or well water, D1, above, will be used in lieu of water stored in drums.

	Based Upon Using Existing Sources Only	Based Upon Total After Modification

1. Quantity of sanitary waste resulting from use of trapped sources (D3 x 2.1 gal/person   a. 1740 gal   b. 1740 gal

2. Can sanitary waste be removed from facility by gravity flow thru existing soil pipes? Yes X No____. If "Yes", estimate quantity of water available for dilution and flushing and enter in E3, below. (One gallon required for each gallon of sanitary waste to be removed). Use excess trapped potable water, D2, above, and/or existing non-potable sources shown in Section C, Form 3706(R).

3. Quantity available for dilution and flushing   a. 3420 gal   b. 3420 gal

(<u>Note</u>: If quantity in E3 equals or exceeds corresponding entry in E1, sanitary waste may be removed without storage and empty drum requirements, below, need not be computed).

4. Sanitary waste requiring storage in drums   a._____ gal   a._____ gal
(E1 - E3)

5. Empty drums required (E4 divided by 15 gal)   a._____ drums   b._____ drums

(<u>Note</u>: Above requirement may be met by utilizing the fiber drum sanitary kits provided as issue stocks, and the steel water storage drums, if any are to be used in the facility. Only 30% of these will be available, since the remainder are required for storing sanitary waste resulting from use of the potable water initially stored therein).

6. Empty fiber drums available (B3 + D3, but not to exceed B1) divided by 50 persons   a._____ drums   b._____ drums

7. Empty water drums available (B4b + D7) x 30%   a._____ drums   b._____ drums

8. Net empty drums required E 5 - (E6 + E7)   a. 0 drums   b. 0 drums

9. Empty drums owner agrees to accept (*)_____.

(*) If owner agreement to trapped water modification is obtained disregard E8a and consider E8b as maximum requirement.

10. Remarks:_____

_____

F. FOOD STOCKS:

1. Total food stocks required (B1, above)......................Spaces **3362**

2. Estimate of non-issue food stocks available
   in facility (Minimum 10 persons, 14 days)................Spaces **570**

3. Existing issue food stocks available, if any
   (B3, above)...Spaces **0**

4. Additional food stocks required
   (F1 minus F2 and F3)..Spaces **2792**

5. Additional food stocks owner agrees
   to accept..Spaces _____

6. Remarks: (Include basis for determination of F2 above) **1000 RESTAURANT MEALS / DAY × 4 DAYS SUPPLY × 2 EQUIV. SHELTER MEALS ÷ 14 DAYS = 570 SPACES**

G. RADIATION KITS:

1. Make appropriate entries below for non-adjoining shelter areas.

Description of Areas (Stories or Location)	Shelter Spaces	Kits Authorized
a. 00, 01, 02	2102	2
b. 03, 04, 05	574	1
c. 06, 07, 08	567	1
09	120	1

2. Total nonadjoining areas **4**   3. Total Kits Authorized **5**

H. NOTES: